



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Jeferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Lead Testing 2016

Fred Hauck
20104 NYS Route 3
Watertown, NY 13601

Project / PO Number: Gov-W
Received: 09/28/2016 15:00
Reported: 10/31/2016 21:08

Analytical Testing Parameters

Client Sample ID: 19
Lab Sample ID: J6J0114-01
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:54

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00310	0.0150	0.00100	mg/L		10/25/16 0800	10/27/16 2030

Analytical Testing Parameters

Client Sample ID: 42B
Lab Sample ID: J6J0114-02
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0336	0.0150	0.00100	mg/L	G	10/25/16 0800	10/27/16 2030

Analytical Testing Parameters

Client Sample ID: 27
Lab Sample ID: J6J0114-03
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00169	0.0150	0.00100	mg/L		10/25/16 0800	10/27/16 2031



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 23
Lab Sample ID: J6J0114-04
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00556, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2032

Analytical Testing Parameters

Client Sample ID: 11
Lab Sample ID: J6J0114-05
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00840, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2032

Analytical Testing Parameters

Client Sample ID: 73
Lab Sample ID: J6J0114-06
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.896, 0.0150, 0.00100, mg/L, GE, 10/25/16 0800, 10/27/16 2034



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 64
Lab Sample ID: J6J0114-07
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00182, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2036

Analytical Testing Parameters

Client Sample ID: 63
Lab Sample ID: J6J0114-08
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0570, 0.0150, 0.00100, mg/L, G, 10/25/16 0800, 10/27/16 2037

Analytical Testing Parameters

Client Sample ID: 28-1
Lab Sample ID: J6J0114-09
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00613, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2038



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 28-2
Lab Sample ID: J6J0114-10
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2038

Analytical Testing Parameters

Client Sample ID: 71
Lab Sample ID: J6J0114-11
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0862, 0.0150, 0.00100, mg/L, G, 10/25/16 0800, 10/27/16 2039

Analytical Testing Parameters

Client Sample ID: 1B
Lab Sample ID: J6J0114-12
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00437, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2040



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 14
Lab Sample ID: J6J0114-13
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00840, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2040

Analytical Testing Parameters

Client Sample ID: 39
Lab Sample ID: J6J0114-14
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0123, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2041

Analytical Testing Parameters

Client Sample ID: 52
Lab Sample ID: J6J0114-15
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0298, 0.0150, 0.00100, mg/L, G, 10/25/16 0800, 10/27/16 2042



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 62
Lab Sample ID: J6J0114-16
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0280, 0.0150, 0.00100, mg/L, G, 10/25/16 0800, 10/27/16 2045

Analytical Testing Parameters

Client Sample ID: 7
Lab Sample ID: J6J0114-17
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0126, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2046

Analytical Testing Parameters

Client Sample ID: 35
Lab Sample ID: J6J0114-18
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00268, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2046



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 69
Lab Sample ID: J6J0114-19
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0464, 0.0150, 0.00100, mg/L, G, 10/25/16 0800, 10/27/16 2047

Analytical Testing Parameters

Client Sample ID: 67
Lab Sample ID: J6J0114-20
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0111, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2048

Analytical Testing Parameters

Client Sample ID: 70
Lab Sample ID: J6J0114-21
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:54

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0143, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2048



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 72
Lab Sample ID: J6J0114-22
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 2.67, 0.0150, 0.00100, mg/L, GE, 10/25/16 0800, 10/27/16 2049

Analytical Testing Parameters

Client Sample ID: 65
Lab Sample ID: J6J0114-23
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0621, 0.0150, 0.00100, mg/L, G, 10/25/16 0800, 10/27/16 2050

Analytical Testing Parameters

Client Sample ID: 24
Lab Sample ID: J6J0114-24
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00121, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2050



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 9
Lab Sample ID: J6J0114-25
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0108, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2052

Analytical Testing Parameters

Client Sample ID: 68
Lab Sample ID: J6J0114-26
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00986, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2054

Analytical Testing Parameters

Client Sample ID: 15
Lab Sample ID: J6J0114-27
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00752, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2055



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 40
Lab Sample ID: J6J0114-28
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0219, 0.0150, 0.00100, mg/L, G, 10/25/16 0800, 10/27/16 2056

Analytical Testing Parameters

Client Sample ID: 17
Lab Sample ID: J6J0114-29
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0334, 0.0150, 0.00100, mg/L, G, 10/25/16 0800, 10/27/16 2056

Analytical Testing Parameters

Client Sample ID: 53
Lab Sample ID: J6J0114-30
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0172, 0.0150, 0.00100, mg/L, G, 10/25/16 0800, 10/27/16 2057



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 22
Lab Sample ID: J6J0114-31
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00741, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2058

Analytical Testing Parameters

Client Sample ID: 47
Lab Sample ID: J6J0114-32
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0367, 0.0150, 0.00100, mg/L, G, 10/25/16 0800, 10/27/16 2058

Analytical Testing Parameters

Client Sample ID: 34
Lab Sample ID: J6J0114-33
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00327, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2100



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 55
Lab Sample ID: J6J0114-34
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.496, 0.0150, 0.00100, mg/L, GE, 10/25/16 0800, 10/27/16 2101

Analytical Testing Parameters

Client Sample ID: 57
Lab Sample ID: J6J0114-35
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0476, 0.0150, 0.00100, mg/L, G, 10/25/16 0800, 10/27/16 2102

Analytical Testing Parameters

Client Sample ID: 4
Lab Sample ID: J6J0114-36
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:03

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00979, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2104



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 3
Lab Sample ID: J6J0114-37
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.323, 0.0150, 0.00100, mg/L, GE, 10/25/16 0800, 10/27/16 2104

Analytical Testing Parameters

Client Sample ID: 66
Lab Sample ID: J6J0114-38
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00292, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2105

Analytical Testing Parameters

Client Sample ID: 41
Lab Sample ID: J6J0114-39
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0131, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2105



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 48
Lab Sample ID: J6J0114-40
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0172, 0.0150, 0.00100, mg/L, G, 10/25/16 0800, 10/27/16 2106

Analytical Testing Parameters

Client Sample ID: 16
Lab Sample ID: J6J0114-41
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.122, 0.0150, 0.00100, mg/L, GE, 10/25/16 0800, 10/27/16 2108

Analytical Testing Parameters

Client Sample ID: 12
Lab Sample ID: J6J0114-42
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0223, 0.0150, 0.00100, mg/L, G, 10/25/16 0800, 10/27/16 2109



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 20
Lab Sample ID: J6J0114-43
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.150, 0.0150, 0.00100, mg/L, GE, 10/25/16 0800, 10/27/16 2109

Analytical Testing Parameters

Client Sample ID: 45
Lab Sample ID: J6J0114-44
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0375, 0.0150, 0.00100, mg/L, G, 10/25/16 0800, 10/27/16 2110

Analytical Testing Parameters

Client Sample ID: 51
Lab Sample ID: J6J0114-45
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0344, 0.0150, 0.00100, mg/L, G, 10/25/16 0800, 10/27/16 2111



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 74
Lab Sample ID: J6J0114-46
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.148, 0.0150, 0.00100, mg/L, GE, 10/25/16 0800, 10/27/16 2113

Analytical Testing Parameters

Client Sample ID: 60
Lab Sample ID: J6J0114-47
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.156, 0.0150, 0.00100, mg/L, GE, 10/25/16 0800, 10/27/16 2113

Analytical Testing Parameters

Client Sample ID: 6
Lab Sample ID: J6J0114-48
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:56

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00609, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2114



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 66
Lab Sample ID: J6J0114-49
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0155, 0.0150, 0.00100, mg/L, G, 10/25/16 0800, 10/27/16 2116

Analytical Testing Parameters

Client Sample ID: 36
Lab Sample ID: J6J0114-50
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00223, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2117

Analytical Testing Parameters

Client Sample ID: 43
Lab Sample ID: J6J0114-51
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00130, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2117



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 50
Lab Sample ID: J6J0114-52
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0269, 0.0150, 0.00100, mg/L, G, 10/25/16 0800, 10/27/16 2118

Analytical Testing Parameters

Client Sample ID: 13
Lab Sample ID: J6J0114-53
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0167, 0.0150, 0.00100, mg/L, G, 10/25/16 0800, 10/27/16 2119

Analytical Testing Parameters

Client Sample ID: 44
Lab Sample ID: J6J0114-54
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0230, 0.0150, 0.00100, mg/L, G, 10/25/16 0800, 10/27/16 2119



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 59
Lab Sample ID: J6J0114-55
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0153, 0.0150, 0.00100, mg/L, G, 10/25/16 0800, 10/27/16 2120

Analytical Testing Parameters

Client Sample ID: 1A
Lab Sample ID: J6J0114-56
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00215, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2122

Analytical Testing Parameters

Client Sample ID: 54
Lab Sample ID: J6J0114-57
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.541, 0.0150, 0.00100, mg/L, GE, 10/25/16 0800, 10/27/16 2124



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 18
Lab Sample ID: J6J0114-58
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2125

Analytical Testing Parameters

Client Sample ID: 2B
Lab Sample ID: J6J0114-59
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00362, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2125

Analytical Testing Parameters

Client Sample ID: 37
Lab Sample ID: J6J0114-60
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00293, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2126



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 38
Lab Sample ID: J6J0114-61
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0549, 0.0150, 0.00100, mg/L, G, 10/25/16 0800, 10/27/16 2127

Analytical Testing Parameters

Client Sample ID: 2A
Lab Sample ID: J6J0114-62
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00511, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2127

Analytical Testing Parameters

Client Sample ID: 61
Lab Sample ID: J6J0114-63
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0274, 0.0150, 0.00100, mg/L, G, 10/25/16 0800, 10/27/16 2128



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 30-1
Lab Sample ID: J6J0114-64
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00392, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2129

Analytical Testing Parameters

Client Sample ID: 30-2
Lab Sample ID: J6J0114-65
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2129

Analytical Testing Parameters

Client Sample ID: 56
Lab Sample ID: J6J0114-66
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.104, 0.0150, 0.00100, mg/L, GE, 10/25/16 0800, 10/27/16 2133



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 8
Lab Sample ID: J6J0114-67
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00638, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2133

Analytical Testing Parameters

Client Sample ID: 49
Lab Sample ID: J6J0114-68
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00605, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2134

Analytical Testing Parameters

Client Sample ID: 5
Lab Sample ID: J6J0114-69
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:03

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0757, 0.0150, 0.00100, mg/L, G, 10/25/16 0800, 10/27/16 2135



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 10
Lab Sample ID: J6J0114-70
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00221, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2135

Analytical Testing Parameters

Client Sample ID: 58
Lab Sample ID: J6J0114-71
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 07:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0207, 0.0150, 0.00100, mg/L, G, 10/25/16 0800, 10/27/16 2136

Analytical Testing Parameters

Client Sample ID: 29-1
Lab Sample ID: J6J0114-72
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00669, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2137



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 29-2
Lab Sample ID: J6J0114-73
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2137

Analytical Testing Parameters

Client Sample ID: 32-1
Lab Sample ID: J6J0114-74
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00461, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2138

Analytical Testing Parameters

Client Sample ID: 32-2
Lab Sample ID: J6J0114-75
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2140



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 33-1
Lab Sample ID: J6J0114-76
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00907, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2142

Analytical Testing Parameters

Client Sample ID: 33-2
Lab Sample ID: J6J0114-77
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2143

Analytical Testing Parameters

Client Sample ID: 31-1
Lab Sample ID: J6J0114-78
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00155, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2143



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0114

Analytical Testing Parameters

Client Sample ID: 31-2
Lab Sample ID: J6J0114-79
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/21/16
Collection Time: 06:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.0150, 0.00100, mg/L, 10/25/16 0800, 10/27/16 2144

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: Action Level
E: Estimated result
MDL: Minimum Detection Limit
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Checklist table with 4 columns: Item, Yes, No, Yes. Items include Custody Seals Intact and/or No Evidence of Tampering, COC/Labels Agree, Received on Ice (or not required).

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795 New York State Department of Health
Microbac Laboratories, Inc. - Chicagoland NY Lab ID No: 12006 Pennsylvania Department of Environmental Protection
PA DEP ID: 68-04863

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Handwritten signature of Michael Fifield

Michael Fifield
Division Manager
10/31/2016 21:08

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Michael Fifield, Project Manager at michael.fifield@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)763-3403 Fax:(607)763-3415
 NY #10796, EPA #NY009936

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Gov - W

Samples must be returned on ice
 MNY Workorder #

Client Information		Billing/Invoice:		Analytix Requested	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES				
Address:	20104 NYS Route 3 Watertown, NY 13601				
Contact:	Ray Filley				
Phone:	315-779-7054				
Project:	Lead Testing				
Quote ID:		PO#:			
Rush TAT Bur. Days:	3 2-5 5-7 7-10	Date Req.:			
Release to DOH:	Yes				
Email Results:	Yes				
Fax Results:	Yes				
	filley@boces.com / fhack@boes.com				

Sample Information		Matrix Type		Number of Containers for Analysis Requested		Comments/Field Data	
Description/Location	Date	Time	Initial				
1 19	9/21	6:54	RF				
2 42B		7:15					
3 27		6:45					
4 23		6:52					
5 11		7:01					
6 73		7:08					
7 64		7:28					
8							

Print Name and Company	Signature	Date/Time	Comments
Sampled: Raymond Filley		9/27 4pm	
Received: DP Beche		9-28 1500	
Received:			
Received:			
Received:			
Received:			



J6J0114

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement.

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)763-3403 Fax:(607)763-3415
 NY #10795, EPA #NY00936

Microbac Laboratories, Inc. Samples must be returned on ice

CHAIN OF CUSTODY

GOV - W

MNY Workorder #

Client Information		Billing/Invoice:	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES		
Address:	20104 NYS Route 3 Watertown, NY 13601		
Contact:	Ray Filley		
Phone:	315-779-7054		
Project:	Lead Testing		
Quote ID:		PO#:	
Rush TAT Bur. Days:	2-5 5-7 7-10	Date Req.:	
Release to DOM: Yes			
Email Results: Yes	rfilley@boCES.com		
Fax Results: Yes	f/hack@boCES.com		

Sample Information			Analysis Requested			Receiving Info (Lab Use Only)		
Description/Location	Date	Time	Initial	Matrix Type	Number of Containers for Analysis Requested	Accepted?	Container Material	Ice: YES NO
1 603	9/21	7:31	RF					YES NO
2 28-1		6:34						YES NO
3 25-2		6:35						YES NO
4 7		7:32						YES NO
5 18		6:46						C W
6 14		6:59						YES NO
7 39		7:13						YES NO
8 52		7:20						YES NO

Print Name and Company	Signature	Date/Time	Comments
Sampled: Raymond Filley	<i>[Signature]</i>	9/27 4pm	
Received: D. Beche	<i>[Signature]</i>	9-28 1500	
Received:			
Received:			
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with it.

Microbac Laboratories, Inc. Samples must be returned on ice
CHAIN OF CUSTODY
 MNY Workorder #

Gov - W

Client Information		Billing/Invoices		Analytix Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCBS					Ice:	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601					Cooler:	YES NO
Contact:	Ray Filley					Sample Temp:	YES NO
Phone:	315-779-7054					Cooler Seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:						Dropoff:	C W
Rush TAT Bur. Days:	2-5 5-7 7-10	PO#:				Accepted?	YES NO
Relocate to DOH:	Yes	Date Req.:				Container Material:	
Email Results:	Yes					Container Size (in MI)	
Fax Results:	Yes					Preservative	
						Comments/Field Data	
Sample Information		Matrix Type		Number of Containers for Analytix Requested			
Description/Location	Date	Time	Initial	Date/Time	Comments		
1 602	9/21	7:30	RF				
2 7							
3 35		6:50					
4 69		6:31					
5 67		7:31					
6 70		7:31					
7 72		6:51					
8 65		7:08					
		7:29					
Print Name and Company		Signature		Date/Time			
Sampled: Raymond Filley				9/27 4pm			
Received: DBKcheke				9/28 1500			
Received:							
Received:							
Received:							
Received:							
Microbac Laboratories (MNY)		By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement to subcontract the analysis to another accredited laboratory.					

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)763-3408 Fax:(607)763-3415
 NY #10796, EPA #NY009936

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

GOV-W

Samples must be returned on ice
 MNY Workorder #

Client Information			Billing/Invoice:			Analytix Requested			Receiving Info (Lab Use Only)		
Name: Jefferson-Lewis-Hamilton-Herkimer, Oneida BOCES Address: 20104 NYS Route 3 Watertown, NY 13601 Contact: Ray Filley Phone: 315-779-7054 Project: Lead Testing Quote ID: PO#: Date Req:			Rush TAT Bur. Days: < 2-5 5-7 7-10 Release to DOH: Yes Email Results: Yes Fax Results: Yes			200.8 Lead P 250 HNO3			Ice: YES NO Cooler: YES NO Sample Temp: YES NO Cooler Seal: YES NO Pickup: YES NO Dropoff: C W Accepted? YES NO Container Material Container Size(In MI) Preservative Comments/Field Data		
Sample Information			Number of Containers for Analysis Requested			Comments					
Description/Location	Date	Time	Initial	Matrix Type							
1 24	9/21	6:49	RF								
2 9		6:58									
3 68		7:31									
4 15		6:59									
5 40		7:14									
6 17		6:19									
7 53		7:21									
8 22		6:52									
Sampled: Raymond Filley Received: D. Bedele Received: Received: Received: Received:			Signature: <i>[Handwritten Signature]</i> Date/Time: 9/27 4pm 9/28 1500								

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement to subcontract the analysis.

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY00936

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Gov - W

Samples must be returned on ice
 MNY Workorder #

Client Information		Billing/Invoice:	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Ontario BOCES		
Address:	20104 NYS Route 3 Watertown, NY 13601		
Contact:	Ray Filley		
Phone:	315-779-7054		
Project:	Lead Testing		
Quote ID:		PO#:	
Rush TAT Est. Days:	< 2-5 5-7 7-10	Date Req.:	
Release to DOH: Yes			
Email Results: Yes	rffilley@boCES.com		
Fax Results: Yes	fhauck@boCES.com		

Sample Information		Analytix Requested		Receiving Info (Lab Use Only)	
Description/Location	Date	Time	Initial	Matrix Type	Number of Containers for Analysis Requested
1 47	9/21	7:22	RF		
2 34		6:31			
3 55		7:20			
4 57		7:20			
5 4		7:03			
6 3		7:05			
7 606		7:29			
8 41		7:14			

Accepted?	Container Material	Container size (in ml)	Prerervative	Comments/Field Data
YES NO				
YES NO				
YES NO				
C W				
YES NO				

Signature	Date/Time	Comments
<i>[Signature]</i>	9/27 4pm	
<i>[Signature]</i>	9/28 1500	

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement.

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

GOV - W

Samples must be returned on ice
 MNY Workorder #

Client Information			Billing/Invoice:		
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES				
Address:	20104 NYS Route 3 Watertown, NY 13601				
Contact:	Ray Filley				
Phone:	315-779-7054				
Project:	Lead Testing				
Quote ID:		PO#:			
Rush TAT Bur. Days:	2-5	5-7	7-10	Date Req:	
Release to DOH:	Yes				
Email Results:	Yes				
Fax Results:	Yes				
	Email: rfilley@boces.com		Fax: fhauck@boces.com		

Sample Information			Analysis Requested			Receiving Info (Lab Use Only)				
Description/Location	Date	Time	Initial	Matrix Type	Number of Containers for Analysis Requested	Accepted?	Container Material	Container Size (in MI)	Preservative	Comments/Field Data
1 48	9/21	7:22	RF			YES				
2 110		6:51				NO				
3 12		7:02				NO				
4 20		7:31				NO				
5 45		7:19				C				
6 51		7:17				W				
7 74		7:11								
8 60		7:25								

Print Name and Company	Signature	Date/Time	Comments
Sampled: Raymond Filley		9/27 4pm	
Received: D. Broche		9-28 1500	
Received:			
Received:			
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in non-contradictory agreement.

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Gov - W

Samples must be returned on ice
 MNY Workorder #

Client Information			Billing/Invoice:		
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES				
Address:	20104 NYS Route 3 Watertown, NY 13601				
Contact:	Ray Filley				
Phone:	315-779-7054				
Project:	Lead Testing				
Quote ID:		PO#:			
Rush TAT Bur. Day:	< 2-5 5-7 7-10		Date Req.:		
Release to DOH:	Yes				
Email Results:	Yes				
Fax Results:	Yes				
	Email Results: filley@boces.com		Fax Results: ffhack@boes.com		

Sample Information			Analyst Requested		
Description/Location	Date	Time	Initial	Matrix Type	Number of Containers for Analysis Requested
1 60	9/21	6:56	RF		
2 610		7:22			
3 310		6:36			
4 43		7:18			
5 50		7:16			
6 13		7:02			
7 44		7:19			
8 59		7:24			

Receiving Info (Lab Use Only)		Comments/Field Data	
Ice:	YES NO		
Cooler:	YES NO		
Sample Temp:			
Cooler Seal:	YES NO		
Pickup:	YES NO		
Dropoff:	C W		
Accepted?	YES NO		
Container Material			
Container Size (in MI)			
Preservative			

Signature	Date/Time	Comment
<i>Raymond Filley</i>	9/27 4pm	
<i>DP Meeker</i>	9-28 1500	

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement.

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY00935

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Gov - W

Samples must be returned on ice
 MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer, Oneida BOCES			Ice:	YES NO	YES NO	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601			Cooler:	YES NO	YES NO	YES NO
Contact:	Ray Filley			Sample Temp:			
Phone:	315-779-7054			Cooler Seal:	YES NO	YES NO	YES NO
Project:	Lead Testing			Pickup:	YES NO	YES NO	YES NO
Quote ID:				Dropoff:	C W	C W	C W
Rush TAT Bur. Days:	3 2-5 5-7 7-10	PO#:		Accepted?	YES NO	YES NO	YES NO
Release to DOH:	Yes	Date Req:		Container Material			
Email Results:	Yes			Container Size(In MI)			
Fax Results:	Yes			Preservative			
				Comments/Field Data			

Sample Information		Number of Containers for Analysis Requested		Comments/Field Data	
Description/Location	Date	Time	Initial	Matrix Type	
1 IA	9/21	6:40	RF		
2 54		7:21			
3 18		6:53			
4 28		6:56			
5 37		6:29			
6 38		7:12			
7 2A		6:50			
8 61		7:30			

Print Name and Company	Signature	Date/Time	Comments
Sampled: Raymond Filley	<i>[Signature]</i>	9/27 4pm	
Received: DP Beecher	<i>[Signature]</i>	9/28 1:00	
Received:			
Received:			
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement.

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY009935

Microbac Laboratories, Inc. Samples must be returned on ice

CHAIN OF CUSTODY

Gov - W

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida-BOCES			Ice:	YES/NO	Container Material	YES/NO
Address:	20104 NYS Route 3 Watertown, NY 13601			Cooler:	YES/NO	Container Size(In MI)	YES/NO
Contact:	Ray Filley			Sample Temp:		Preservative	
Phone:	315-779-7054			Cooler Seal:	YES/NO	Accepted?	YES/NO
Project:	Lead Testing			Pickup:	YES/NO	Container Material	
Quote ID:				Dropoff:	C W	Container Size(In MI)	
Rush TAT Bur. Days:	2-5 5-7 7-10			Accepted?	YES/NO	Preservative	
Release to DOH:	Yes			Number of Containers for Analysis Requested		Comment/Field Data	
Email Results:	Yes						
Fax Results:	Yes						
Sample Information		Matrix Type		Signature		Date/Time	
Description/Location	Date	Time	Initial				
1 30-1	9/21	6:39	RF				
2 30-2		6:40					
3 56		7:26					
4 8		6:58					
5 49		7:16					
6 5		7:03					
7 10		7:01					
8 58		7:24					
Print Name and Company		Signature		Date/Time		Comments	
Sampled: Raymond Filley				9/27 4pm			
Received: D Bleeker				9-28 1500			
Received:							
Received:							
Received:							
Received:							
Microbac Laboratories (MNY)		By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement to subcontract the analysis to another accredited laboratory.					

Microbac Laboratories, Inc. Samples must be returned on ice
CHAIN OF CUSTODY

Gov - W

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer, Oneida BOCES			Ice:	YES NO	YES NO	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601			Cooler:	YES NO	YES NO	YES NO
Contact:	Ray Filley			Sample Temp:			
Phone:	315-779-7054			Cooler Seal:	YES NO	YES NO	YES NO
Project:	Lead Testing			Pickup:	YES NO	YES NO	YES NO
Quote ID:		PO#:		Dropoff:	C W	C W	C W
Rush TAT Bus. Days:	< 2-5 5-7-10	Date Req:		Accepted?	YES NO	YES NO	YES NO
Release to DOH: Yes				Container Material			
Email Results: Yes	filley@boces.com			Container Size (in Mi)			
Fax Results: Yes	filley@boces.com / ffilley@boces.com			Preservative			
Sample Information		Number of Containers for Analysis Requested		Comments/Field Data			
Description/Location	Date	Time	Initial	Matrix Type			
1 29-1	9/21	6:37	RF				
2 29-2		6:37					
3 32-1		6:43					
4 32-2		6:43					
5 33-1		6:42					
6 33-2		6:43					
7 31-1		6:40					
8 31-2		6:41					
Print Name and Company		Signature		Date/Time			
Sampled: Raymond Filley				9/27 4PM			
Received: D. B. Stehke				9-28 1500			
Received:							
Received:							
Received:							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this notice.